

Department of Energy

Richland Operations Office P.O. Box 550 Richland, Washington 99352

07-AMCP-0083

JAN 3 I 2007

Ms. Debra McBaugh, Section Head Environmental Radiation Section Washington State Department of Health P.O. Box 47827 Olympia, Washington 98504

Mr. David Grant Aquatic Resources Division State of Washington Department of Natural Resources 713 East Bowers Road Ellensburg, Washington 98926



Addressees:

DEPARTMENT OF NATURAL RESOURCES LAND LEASE MONITORING REPORT FOR NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT NO. WA 002591-7 OUTFALL 001 – DECEMBER 2006

The purpose of this letter is to forward for your review, the attached 300 Area Treated Effluent Disposal Facility, Department of Natural Resources monthly monitoring data, as required by Aquatic Lands Sewer Outfall Lease 20-013357. Monthly monitoring data for radionuclides present in the effluent are provided in the attached table. The data indicate that all values monitored are well below State guidelines. Reporting of monthly composite sample results are provided and transmitted to the Washington State Department of Health, according to Exhibit C of the lease. This report covers the reporting period from November 21, 2006, through December 19, 2006.

If you have any questions, please contact me, or you may contact Mark French of my staff, on (509) 373-9863.

Sincerely,

AMCP:OMH

Attachment

cc: See Page 2

for the Central Plateau

cc w/attach:

G. Bohnee, NPT

A. L. Boyd, EPA

K. A. Conaway, Ecology

R. H. Engelmann, DFSH

D. L. Halgren, FHI

S. Harris, CTUIR

R. Jim, YN

K. Ogle, EPA (Seattle)

M. Priddy, WDOH

D. G. Ranade, FHI

E. R. Skinnarland, Ecology

H. T. Tilden, PNNL

Administrative Record (300 Area Treated Effluent

Disposal Facility Liquid Effluent) and (Aquatic Lands Sewer Outfall Lease 20-013357)

Environmental Portal

Hanford Site 300 Area Treated Effluent Disposal Facility

Monthly Monitoring Data

December 2006

Analysis	Result (pCi/L)	State Standard (pCi/L)
Total Alpha	BDL ⁽²⁾	15 ⁽³⁾
Total Beta	2.30	50 ⁽³⁾
GEA ⁽¹⁾ – ⁶⁰ Co	BDL ⁽²⁾	3,000 ⁽⁴⁾
¹³⁷ Cs	BDL ⁽²⁾	1,000 ⁽⁴⁾
Tritium	BDL ⁽²⁾	20,000 ⁽³⁾

(1) GEA: Gamma Energy Analysis

(2) BDL: Below Detection Limit

Washington Administrative Code 246-221-290 (Table II, effluent water)

Standards for total alpha, total beta, and tritium from Department of Natural Resources Aquatic Resources Lease 20-013357